

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/05/2026-27

Dated: 19/05/2026

It is certified that an inspection team headed by Umesh Kumar (Chemist) (Name of Officers with designation) from U.P. JAL NIGAM (Rural) PHED inspected the Lucknow Public School Nav Abad Abul Hasan Nadvi Colony Near Champa Devi Mandir Ahiyaraipur Raebareli (Name & Address of the school) on 15/05/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no CHEMICAL TEST/24721/2026-027 dated 19/05/2026 of District Level Water Analysis Laboratory, Raebareli (PHED Lab) certified that the Lucknow Public School, Ahiyaraipur Raebareli (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 Year

Signature with Seal: Umesh

Name : Umesh Kumar

Designation : Chemist

Name & Address of the Office / Department: U.P.
Jal Nigam (Rural) Raebareli.

To
Lucknow Public School
Raebareli
(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Amrit
PRINCIPAL
Lucknow Public School
Rae Bareil

[Signature] LBS™
MANAGER
LUCKNOW PUBLIC SCHOOL
LUCKNOW



Analysis Report

District Level Water Analysis Laboratory, L.P. Jai Nigam
Sultaapur road (Rabi Raibareh)



Sl. No.	Client Name	Address	City	State	Pin Code
1	LUCKNOW PUBLIC SCHOOL	LUCKNOW	LUCKNOW	UP	226001

Customer Details	
Client Name & Address	LUCKNOW PUBLIC SCHOOL, SULTAAPUR ROAD, RAIBAREH, LUCKNOW, U.P.
Client No. & Date	3926 / 2020

Basic Details Of Sample	
Quality	Drinking
Class / Panel / Lot	Block
Habitat	Village
Water Source	Hand Pump
Quality of Sample	Surface
Receiving Date	15/07/2020
Sample Description	Drinking Water
Analysis Start Date	18/07/2020
Analysis Completion Date	18/07/2020

Environmental Condition	
Temperature	25.3°C
Relative Humidity	100%

S.No.	Analyzed parameters	Unit of Measurement	Observed Value	Specified Values as per IS: 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternative source	
1	2		3	4	5	6
1	Odour		Agreeable	Agreeable	Agreeable	IS: 3025 (Part 5):2018 (RA: 2023)
2	Taste		Agreeable	Agreeable	Agreeable	IS: 3025 (Part 5):2018
3	Colour	Hazen	1	5	15	APHA 24 th Edition -1130 Colour Method B: Platinum Chloride Visual Comparison 2020
4	pH @ 25.0°C		7.0-8.5	6.5-8.5	6.5-8.5	IS: 3025 (Part 10): 2012 (RA: 2023)
5	Turbidity	NTU	0.40	1.00	5.00	IS: 3025 (Part 10): 2012
6	TDS	mg/l	500	500	2000	IS: 3025 (Part 10): 2012
7	Chloride	mg/l	250	250	1000	IS: 3025 (Part 10): 2012 (RA: 2023)
8	Total Alkalinity	mg/l	500	500	600	IS: 3025 (Part 10): 2012
9	Total Hardness	mg/l	500	500	600	IS: 3025 (Part 10): 2012 (RA: 2023)
10	Sulphate	mg/l	200	200	400	APHA 24 th Edition -5004 Method B: Turbidity Method 2020
11	Iron	mg/l	0.30	0.30	No Relation	APHA 24 th Edition -5004 Method B: Phenanthroline Method 2020
12	Calcium as Ca	mg/l	75	75	100	IS: 3025 (Part 10): 1991 (RA: 2023) Titrimetric Method
13	Magnesium as Mg	mg/l	30	30	100	IS: 3025 (Part 10): 1991 (RA: 2023)
14	Fluoride	mg/l	1.5	1.5	1.5	APHA 24 th Edition -4500-F method C: Electrode Method
15	Nitrate	mg/l	45	45	No Relation	APHA 24 th Edition -4500-NO3 Method B: UV Spectrometry Method 2011

- Note:
- This Certificate refers only to the particular sample(s) submitted for testing.
 - This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 - The test results reported in this certificate are valid at the time of and under the stated conditions of measurement.
 - Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of test reports unless otherwise specified.
 - Sample Collection was submitted by the customer, if only Tested in Laboratory.
 - The Result apply to the Samples Received.
 - Source is not verified by the Laboratory.

Amit
PRINCIPAL
Lucknow Public School
Rae Bareilly



End Of Test Report

Contact details: Email: info@lpsraebareilly.com Mobile No: 9839000000

L.P.S.
MANAGER
LUCKNOW PUBLIC SCHOOL
LUCKNOW