

The Manager,

LUCKNOW PUBLIC SCHOOL

SECTOR-C, POCKET-9, ANSAL API, SUSHANT GOLF CITY, SULTANPUR ROAD, LUCKNOW

UTTAR PRADESH, LUCKNOW, 226030

(M: 0522-6180041)


SUBJECT: -FRESH AFFILIATION UP TO SENIOR SECONDARY LEVEL-regarding.**Ref : Application No.: - SS-00287-2526 Dated:07/05/2024**

Sir/Madam,

This is with reference to school application on the subject cited above. I am directed to convey approval of the Board for Fresh Affiliation up to Senior Secondary Level as per details given below :

Affiliation No used as User ID for both OASIS and LOC/Registration System	2134109
School No	72115
Password for OASIS and LOC/Registration Systems is same as that used for Affiliation Application.	
Affiliated for	Senior Secondary School Examination Class 1 to 12
Category	Fresh Affiliation
Period of affiliation	01.04.2024 to 31.03.2029
Year and Month From which admission can be taken in Class-IX/XI	1 April,2024
Year and Month in which first batch of Class-X/XII will appear in board examinations	1 April,2026

Sl. No.	The school is directed to ensure that :
1	The total number of sections for Bal Vatika is restricted to 09 (03 each for Bal Vatika I,II & III respectively). Further, the total number of sections for classes 1st to 12th shall be restricted to 36 only out of which not more than 1/3rd sections may be used for senior secondary level classes. The optimum number of the students shall be restricted to 40 in each section. Any further increase of sections shall be subject to specific approval of the Board on the basis of the request of the school as per affiliation bye law and availability of class rooms of 500 sq ft and greater in dimension.
2	The Biology Lab and the Chemistry Lab for the senior secondary level have not been arranged with proper infrastructure and safety measures as per the SoPs and the Board guidelines vide circular no 11/2022. The gas pipeline /facility in chemistry lab is passing over the racks having concentrated chemicals. No exhaust fans, safety manual for users and adequate seating arrangement seen in the labs. Further, plastic stools are not recommended due to heating facility in Biology and Chemistry labs. School is directed to follow the Board guidelines in circular no 11./2022 and upgrade the labs accordingly and upload the compliance with video link within 03 months on SARAS portal.
3	The Composite Science lab is under stocked and also has not been arranged with recommended safety measures as notified in SoPs vide circular no 11/2022, like exhaust fans, safety manuals for users, safe seating arrangements etc as per Board guidelines. School is directed to upgrade the lab with recommended infrastructure and standard safety measures and upload the compliance with video link within 03 months on SARAS portal.



PRINCIPAL

LUCKNOW PUBLIC SCHOOL
ANSAL API, SECTOR-C, GOLF CITY
LUCKNOW



LPS™
MANAGER
LUCKNOW PUBLIC SCHOOL
LUCKNOW

4	Math lab has not been covered during the IC videography, school is directed to arrange the math lab with recommended infrastructure and facilities as per the SoPs and Board guidelines notified vide circular no 11/2022 and upload the compliance with video link within 03 months on SARAS portal.
5	The CwSN toilets arranged by the school are not safe and as per the Board guidelines notified vide circular no 05/2023 and also not available at each floors separately for Boys and Girls. The side support bars to the commodes are with sharp edges and may be fatal to the wheelchair bound person to use. School is directed to re-arrange the CwSN toilets at each floors with recommended infrastructure as per guidelines and upload the compliance with video link within 03 months on SARAS portal.
6	Electric poles are seen within the school campus (video ref time -02:56) which have not even been cordoned off from access to the students and raises the safety concern for the students and the staff. School is directed to remove the electric poles with wires from the campus and upload the compliance on SARAS portal with video link within 03 months.
7	School shall ensure the mandatory training of its teachers from CoE, CBSE, Prayagraj and shall upload the compliance on SARAS portal within 03 months.

Compliance of the above mentioned points shall be submitted within 03 months on the SARAS Portal. Failure to comply within the prescribed time shall invite financial penalty @ Rs. 50,000/- every month until compliance is submitted and shall debar the school from filling the registration and LOC of students class IX to class XII , as the case may be.

The approval of the Board as mentioned above, is subject to the following conditions:-

1. The school shall be responsible for its genuineness of the documents/ data/ information uploaded by the school. In case of any discrepancies, action will be initiated against the school as per Affiliation Bye - Laws-2018.
2. The school shall follow the RTE Act, 2009 and instructions issued thereon by the CBSE/Respective State /UT Govt. from time to time. The school will also abide by the conditions prescribed, if any, by the State Government concerned.
3. The School shall apply online for extension of affiliation along with the requisite fee and other documents as per Rule 10.3 of Affiliation Bye Laws.
4. The school shall go through the provision of Affiliation and Examination Bye Laws and subsequent amendment therein as well as circulars and guidelines /instructions issued by the Board time to time and keep a copy thereof for reference purpose and is also advised to regularly visit CBSE websites i.e., <http://cbseacademic.nic.in/> & <http://cbse.nic.in/> for updates.
5. The school shall renew mandatory certificates from time to time.
6. The school shall be solely responsible for any legal consequences arising out of the use of school name/logo/society/trust or any other identity /activity related to running of school affiliated to CBSE. All legal expenses incurred by the Board, if any, arising out of these circumstances, shall be borne by the school.
7. Concerned Regional Office is requested to create new email id of school as per direction issued by controller of examination. This E Mail ID is used for communication with CBSE only.
8. The school shall not remove the documents and videography links in the mandatory disclosure section of its website.
9. The school shall follow the SOPs of the Board for its Laboratories, Library and sports facilities issued by the Board vide circular no 11 dated 04.10.2022.

If the compliance is not submitted within the stipulated 3 months , the Board may enhance the penalty amount and debar the schools from filling up registration/LOC details of students of classes IX to XII, as the case may be, in the next academic session i.e. 2024-25.

DEPUTY SECRETARY/JOINT SECRETARY (AFF.)


PRINCIPAL
LUCKNOW PUBLIC SCHOOL
ANSAL API, SECTOR-C, GOLF CITY
LUCKNOW


MANAGER
LUCKNOW PUBLIC SCHOOL
LUCKNOW